

Maximum Incoming
Gas Pressure 14.0"wc
LP or NAT
Pressure required
Nat Gas 7"wc
Pro Gas 11"wc

Outgoing Gas to
Burners/Pilots

Regulator pressure
adjustment

Outgoing
Gas to the
Burners/Pilots

Test spigot

Natural Gas 3.5"wc
Propane Gas 10.0"wc

